

## City of Galion Weekly Reports Week of Dec. 5, 2016

### **Service Department**

This Week: OUPS locates, leaf pick up, pothole patching

Next Week:

- Street Sweeper
- Leaf Pickup
- Snow and Ice operations prep trucks
- Sewer jetting / cleaning
- Pothole patching
- Pavilion site prep

Long-term Projects:

- Rebuild softball fields at Peco
- Set poles and cable to protect Amick grass areas and Disc Golf Course (winter project)
- Depot pavilion site prep

### **Water Treatment Plant/Waste Water Treatment Plant**

Issues for Immediate Attention: Water Treatment Plant operations and maintenance, ongoing harmful algae bloom (HAB) sampling, issues with high service pumps, issues with ferric chemical pump, control screen failure on bar screen at WWTP.

This Week:

- HAB sample sent to EPA
- Cleaned Water Treatment Plant
- Ongoing issues with #4 high service pump
- WWTP processing sludge
- Sent process board from bar screens back for warranty replacement
- Aerator tank

Next Week:

- Plant maintenance and operations,
- Start to feed polymer for addition coagulation
- Check lifts for proper operations
- Start process for drying bin bearing replacement

Long-term Projects:

- Itemizes repair and replacement of pool equipment and building
- Replace filter sand
- Continue sampling and plant repair as needed
- VFD for second raw water pump

- High service pump repair
- Replace filter actuator and valve
- Backup power supply and screw pump replacement
- Design back up sludge discharge system